

HOME SOLUTIONS & MATERIALS LTD

TEL.: +35723833536, +35723814220

FAX: +35723814221

Email: homesolutions@cytanet.com.cy

ecoBETA®
LYKKEBO miljø & design
Water Saving Systems



Rådgivning & Beregning

WATER CONSUMPTION SAVINGS

DATE: 01.11.2008

CLIENT: **ANASTASIA BEACH HOTEL**

WATER SAVING DEVICES INSTALLED

TYPE:	WC D/F SIPHON	AMOUNT:	224
TYPE:	SINK SAVERS 2.5L	AMOUNT:	307
TYPE:	SHOWER SAVER 8L	AMOUNT:	224
TYPE:	TURBO SHOWER	AMOUNT:	224

Without water saving devices.

Period

01-31/10/2007

Meter reading 1	0	
Meter reading 2	0	
Days between readings	31	
Persondays for the period	12837	
Total water consumption		4383
Water consumption /day		141,387097
Water consumption /person/day		0,34143491

With water saving devices

Period

01-31/10/08

Meter reading 1	0	
Meter reading 2	0	
Days between readings	31	
Persondays for the period	12012	
Total water consumption		2228
Water consumption /day		71,8709677
Water consumption /person/day		0,18548119

Savings

Percentage overall saving	49,1672371
Percentage saving /person/day	45,6759759